

DEVELOPERS AND ENGINEERS “PIPE SELECTION”

Although the Valparaiso City Utilities is predominately a ductile-iron pipe utility, it realizes that there are instances in which other materials may be desired because of deflection, highly corrosive soils, or other physical, special conditions.

In these instances, the engineer is advised to direct the concern to the Utilities Distribution Manager for review.

The engineer may also refer to Sections 02110 and 02235 of the Utilities Construction Specifications.